



13 June 2013

Danilo Zabala
Chief Executive Officer
Dataplanet N.V.
Kaya Seru Mahuma z/n
Willemstad, Curacao

Re: Tier IV Certification of Design Documents for the Dataplanet N.V. – Blue NAP Americas
Datacenter, CU-1 in Willemstad, Curacao

Dear Danilo Zabala,

Uptime Institute Professional Services is pleased to announce the Dataplanet N.V. – Blue NAP Americas Datacenter, CU-1 as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 25 September 2012 and 21 June 2013.

This Certification supersedes the Tier IV Certification of Design Documents for the Curacao Technology Exchange N.V. – CTEX Data Center dated 13 June 2013.

This Certification recognizes the Dataplanet N.V. – Blue NAP Americas Datacenter, CU-1 design as supporting any planned work or unplanned faults to the site infrastructure *without* disrupting operations, as limited by the uninterruptible power supply (UPS) capacity of 2,000 kilovolts ampere (kVA)/2,000 kilowatts (kW) based on a connected load power factor of 1.0 for the CU-1 building. The 2,000-kW IT load for the CU-1 building will be deployed in three distinct phases, with 400 kW in Phase 1; 800 kW in Phase 2; and 800 kW in Phase 3.

Tier IV criteria are founded on the capability to detect and isolate a fault within a facility's critical systems while sustaining the critical load and *without an impact to the delivery of power and cooling to the critical areas*. Although the systems are designed with Fault Tolerant criteria, certain operations-related errors, such as inadvertent activation of equipment-level EPO features, or malicious intervention, may still impact critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

Congratulations on this achievement.

Sincerely,

A handwritten signature in dark ink, appearing to read "Christopher Brown".

Christopher Brown
Chief Technical Officer